



883-2023 ADDENDUM 2

SUPPLY & INSTALLATION OF NEW PVC POOL MEMBRANE & RELATED WORKS – ST. VITAL OUTDOOR POOL – 5 DES MEURONS STREET

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL

ISSUED: November 27, 2023
BY: Lou M. Chubenko
TELEPHONE NO. 204 470-7881

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, **December 14, 2023.**

QUESTIONS AND ANSWERS

- Q1: Under Section D2.2(b) it states: To complete any necessary localized repairs to existing concrete pool substrate surfaces to accept new pool PVC membrane and associated pool components, as required.
- A1: Clarification: The responsibility for the preparation of the existing pool basin concrete substrate surfaces which includes the concrete resurfacing and repairs shall be by Others. The intent is to have a separate contractor, under a separate Contract/Tender undertake this Work.
- Q2: Under Section D2.2(h) it states: Replacement of main drains, skimmers, return inlets/outlets, vacuum ports, lane rope anchors, etc. to meet the current requirements of the plumbing code as well as the Public Health Act and Regulation MR132/97.
- A2: Clarification: Replacement of main drains, skimmers, return inlets/outlets, vacuum ports, lane rope anchors, etc. as required/necessary to achieve a successful underwater termination of the new pool liner at these fittings.