

## CONSTRUCTION STANDARDS

## MUNICIPAL EXCAVATION STANDARDS

- \*\* DISCLAIMER \*\***  
THE INDICATION OF OTHER PARTIES ON THIS DRAWING ARE FOR TRENCH  
LOCATION PURPOSES ONLY. REFER TO THE OTHER PARTY'S DRAWINGS FOR  
DESIGN DETAILS.

[illegible]


AUTHORITY	NOTIFIED	NOT REQ'D	OBTAINED
DEPT. OF HIGHWAYS		X	
COWMUNICIPAL ADMINISTRATIVE	2025-04-		
M.T.S.		X	
GAS		X	
EASEMENTS		X	
CONTROL CENTER		X	
RAILWAY		X	
CATV		X	
DISTRICT	2025-05-		

NOT TO BE USED  
FOR CONSTRUCTION

## PRIOR TO CONSTRUCTION FOR LOCATION OF EXISTING WATER, WASTEWATER AND LAND DRAINAGE UTILITIES

INSTALLED			
Quantity	Fixture Type	Wattage	Pole Type
0	LED	40	SHARED
0	LED	50	SHARED
4	LED	60	EXCLUSIVE
0	LED	90	EXCLUSIVE
4	LED	150	EXCLUSIVE
0	LED	209	EXCLUSIVE

REMOVED			
Quantity	Fixture Type	Wattage	Pole Type
0	LED	91	EXCLUSIVE
4	LED	138	EXCLUSIVE
0	LED	150	EXCLUSIVE
0	LED	209	EXCLUSIVE
0	LED	400	SHARED



REEL NUMBER	MANUFACTURER	MANUFACTURE DATE

NO.	DAT	REVISIONS	BY	CK D.	APP		AREA NUMBER	MANITOBA HYDRO DISTRIBUTION ENGINEERING		
00	2025-06-	ISSUED TO CONSTRUCTION	PRL	RD			5201	WO# P:41407                      NETWORK # 4308964		
							STATION NUMBER	CSC: CITY CENTRE		
							1506	CUSTOMER SERVICE PROJECT:		
							FEEDER NUMBER	CITY OF WINNIPEG ROAD RENEWAL ON RUPERT AVE		
DRAWING NUMBER		REFERENCE DRAWINGS				DRAW	2.4/4.16KV	INSTALL 4-35' DAVITS, 4-15' POST TOPS, #4 AL CN,		
		City Of Winnipeg Approval				CHECK		LUMINAIRES, 50MM CONDUIT FROM MAIN ST TO LILY ST		
						SCAL		1:750		
						DAT		1-04707-DC-50000-0671		
						2025-04-17		SHT 01                      RE V 00		