

		<u>co</u>	NSTRUCTION NOTES:		
32.0		1.	ALL WORK AND MATERIALS TO LATEST REVISION OF THE CITY CONSTRUCTION SPECIFICATIO	OF WINNIPEG STANDARD	
		2.	LEGAL PLAN AND UNDERGROU CITY OF WINNIPEG LBIS.	IND INFORMATION FROM	
		3.	B. CONTRACTOR TO TAKE PRECAUTIONARY STEPS TO AVOID DAMAGE FROM CONSTRUCTION ACTIVITIES TO TREES WITHIN THE LIMITS OF CONSTRUCTION. REFER TO SPECIFICATION E6 PROTECTION OF EXISTING TREES.		
31.5		4.	LOCATION OF EXISTING UTILIT CONFIRMED IN THE FIELD BY T		
		5.	ADJUST EXISTING WATER VALVES AND WATER SERVICE CURB STOPS TO GRADE. WATER SERVICES TO BE INSULATED AS PER SD-018 WITH 100mm THICK x 2700mm WIDE TOP OF INSULATION OR RENEWED/INSULATED AS INDICATED ON PLAN IN ACCORDANCE TO CW-2110. VALVES TO BE OPERATED BY CITY OF WINNIPEG CREWS		
		6.	MODIFIED BARRIER CURB SD-2 INTERSECTION RADII.	03C TO BE USED AT ALL	
31.0		7.	LIMITS OF SIDEWALK RECONSTRUCTION TO BE FINALIZED IN THE FIELD BY THE CONTRACT ADMINISTRATOR. INSTALL SIDEWALK EXPANSION JOINT AS PER SD-228AA. CONTRACT ADMINISTRATOR WILL LAY OUT FINAL LOCATIONS OF SIDEWALK EXPANSION JOINTS.		
30.5		8.	ADJUST MANHOLE AND CATCH BASIN RIMS TO NEW GRADES. REMOVE AND REPLACE ALL MANHOLE FRAMES AND COVERS IN PAVEMENT. REPAIR/REPLACE BENCHING AND RISERS AS DIRECTED BY THE CONTRACT ADMINISTRATOR.		
		9.	D. CONSTRUCT SIDEWALK CONNECTIONS TO PRIVATE APPROACHES AS PER SD-228A TO LIMITS AS SHOWN. AL PRIVATE SIDEWALKS TO BE ADJUSTED TO NEW SIDEWALK OR TOP OF CURB ELEVATIONS AS REQUIRED. SIDEWALKS TO BE REPLACED WITH LIKE MATERIALS.		
30.0 5		10.	<ol> <li>CB LEADS AND CP LEADS TO BE INSTALLED TO INVERT ELEVATIONS AS SHOWN. ALL CB LEADS TO BE INSTALLED AT MIN 1.0% SLOPE AND AS DIRECTED BY CONTRACT ADMINISTRATOR. ALL CP LEADS TO BE INSTALLATED AT MIN 2.0% SLOPE AND AS DIRECTED BY CONTRACT ADMINISTRATOR.</li> </ol>		
		11.	1. LIMITS OF BOULEVARD GRADING TO BE FINALIZED IN THE FIELD BY THE CONTRACT ADMINISTRATOR.		
		12.	CONTRACTOR TO CONFIRM LC SEWER REPAIRS AS INDICATED PERFORMING VIDEO INSPECTION THE CONTRACT ADMINISTRATO CONSTRUCTION.	D ON THE DRAWINGS BY ON AND REVIEWING WITH	
		13.	13. LAMP STANDARDS, HYDRO POLES AND ANCHORS THAT REQUIRE TEMPORARY SUPPORT, REMOVAL OR REPLACEMENT, TO BE DONE AT THE EXPENSE OF THE CONTRACTOR, AS NECESSARY. REFER TO SPECIFICATION E24-WORKING AROUND MANITOBA HYDRO POLES.		
		14.	14. INSTALL 6.0 m OF 150 mm SUBDRAIN TO CATCH BASINS II BOTH DIRECTIONS WITH END CAPS PARALLEL TO ROADWAY AS PER SD-245 OR AS NOTED.		
		<ol> <li>COMPLETE CATCH BASIN/CATCH PIT CURB AND GUTTER INLET ISOLATIONS IN ACCORDANCE WITH SD-220D DETAILS.</li> </ol>			
		<ol> <li>CONSTRUCT 150 EXPOSED FACE BARRIER CURB AS PER SD-200A, OR AS OTHERWISE NOTED.</li> </ol>			
		17. CONSTRUCT 75 LIP CURB WITH INTEGRAL APPROACH SD-202CA.			
		18. SIDEWALK RENEWALS TO PROVIDE 2.0% CROSSFALL TOWARDS ROAD OR AS NOTED.			
		19. ADD 200.000 TO ABBREVIATED ELEVATIONS TO OBTAIN GEODETIC ELEVATIONS.			
		20.	ALL DIMENSIONS ARE TO BACK	OF CURB.	
			TENDER DRAWING		
			USED FOR CONSTRUCTIO	N	
		Certificate of Authorization Tetra Tech Canada Inc.			
					METRIC WHOLE NUMBERS INDICATE MILLIMETRES DECIMALIZED NUMBERS INDICATE METRES
F MANIFORM	<u>e</u>	THE	E CITY OF W		
NG H 25 SSIDNAL SSIDNAL	Winning	PUBL	IC WORKS DEPARTINEERING DIVISION		
	2025 LOCAL STREET			CITY DRAWING NUMBER P-3593-5	
	ASPHALT RECONSTR			SHEET OF 12 DWG. NO.	
DRAWING NO.	WEST GATE (BLANCH		• • • •	C0005	

PLAN AND PROFILE