



February 12, 2025

Attention: **Andre Dumont**
Municipal Civil Engineer, Western Canada
Ph: 204-590-9096
andre.dumont@aeacom.com

RE: St. Charles Detailed Design & Contract Administration Services - 60686223 - MTI Crossing Permit Application

BellMTS has reviewed your request for the proposed crossing and to work within proximity of Bell MTS **VF & Fiber facilities** in the **NE 36-10-01E**. BellMTS records show working **VF & Fiber Facilities** in the location of **NE 36-10-01E**, as indicated on your attached survey drawing.

Bell MTS has no objections, and will give their consent to **City of Winnipeg** cross buried Bell MTS facilities, provided the following conditions are met and adhered to;

- The working BellMTS cable(s) must be accurately located and staked prior to starting any construction.
- BellMTS must maintain unhindered access to the affected cable for future repair and or replacement.
- Voice Frequency facilities requires a minimum separation of 1 meter between the Bell MTS cable and any culverts or pipelines, .3 meter separation between the BellMTS cable and any electrical cable, and a minimum of 1.0 meters of ground cover between the BellMTS cable and finished grade.
- The excavation around the VF facility (s) is the responsibility of the Applicant, at no cost to Bell MTS, and BellMTS will provide our personnel and material at no cost to the Applicant.
- Any rearrangements that are required or damage that occurs to Bell MTS Fiber\VF cable(s), during the crossing of BellMTS facilities, will be 100% the expense of **City of Winnipeg**

To arrange for cable locates from BellMTS, please use the clickbeforeyoudigMB.com Portal for Manitoba.

If you require any further information, please call **Sylvie Leurquin** at 204-941-7023

Thank you,

BellMTS

Sylvie Leurquin
Ph: 204-941-7023
Sylvie.leurquin@bellmts.ca

