

Information Bulletin

ULC Listing for Fire Rated Cables

ULC now has a number of products listed as fire-resistive cables acceptable for installation where conductors are required to be protected against exposure to fire. To view the list on the ULC website, users should enter “**FHJRC**” as the ULC Category Code in the Basic Search area at:

<http://database.ul.com/cgi-bin/XYV/template/LISCANADA/1FRAME/index.html>.

Cable specifiers and installers should note that each cable is required to be installed as a system with specific installation methods and materials in order to achieve the listed fire rating. The system number is noted in the FHJRC table for each cable and can be viewed by entering “**FHITC**” as the ULC Category Code at the link above.

At the time of posting of this bulletin, the following have been listed as fire-resistive cables by ULC:

- Marmon VITALink Type MC (metal clad) for use in System No. 120
- Pentair Pyrotenax Type MI (mineral insulated) for use in System No. 1850
- Radix DuraLife Type FPL Shielded (power-limited fire alarm cables) for use in System No. 28B

Users are encouraged to check the ULC website to confirm current listing results prior to specifying or installing fire resistive cables