

PAGE 1

January 30, 2020

T. | Tél.: 204-986-4684

F. | Fax: 204-339-2147

winnipeg.ca/waterandwaste

Manitoba Conservation and Climate Environmental Compliance and Enforcement Branch 1007 Century Street Winnipeg, MB R3H 04W

Attention: Ms. Shannon Kohler, Regional Director

RE: DECEMBER 2019 MONITORING REPORTS FOR THE CITY OF WINNIPEG WATER POLLUTION CONTROL CENTRES

The December 2019 Monitoring Reports for the West End Water Pollution Control Centre (WEWPCC), North End Water Pollution Control Centre (NEWPCC), and South End Water Pollution Control Centre (SEWPCC) are attached. This information is provided under compulsion of law in accordance with the requirements under the Environment Act Licences #2669 E RR, #2684 RRR and #2716 RR.

Please note the following respecting the report for Licence #2669 E RR:

- 1. There were no 24-hour composite samples on December 1 and 2 due to a sampler malfunction and on December 18 due to a power outage.
- 2. The TSS results met the licence limit in December.
- 3. The cBOD5 results met the licence limit in December.
- 4. The ammonia results and the total phosphorus and total nitrogen thirty-day rolling averages met the licence limits in December.
- 5. There was no grab sample on December 1 due to a technician error.
- 6. There were no results for fecal coliform and *E. coli* and on December 11 due to a technician error; the monthly geometric means for fecal coliform and *E. coli* met the licence limits in December.

Please note the following respecting the report for Licence #2684 RRR:

- 1. The TSS results met the licence limit in December.
- 2. The BOD5 results met the licence limit in December.
- 3. There was no grab sample on December 2 because there was no access to the sample point due to maintenance activities.
- 4. The monthly geometric means for fecal coliform and *E. coli* met the licence limits in December.



T. | Tél.: 204-986-4684

F. | Fax: 204-339-2147

winnipeg.ca/waterandwaste



Please note the following respecting the report for Licence #2716 RR:

- 1. The TSS results met the licence limit in December.
- 2. The cBOD5 results met the licence limit in December.
- 3. The monthly geometric mean for *E. coli* met the licence limit in December.

Please let me know of any concerns or questions respecting this submission. I can be reached by telephone at 204-986-8359 or by email at rgrosselle@winnipeg.ca.

Yours sincerely,

Original signed by:

R. Grosselle Manager of Environmental Standards

NC

Enclosures

cc: M. L. Geer, CPA, CA (e-mail) C. Carroll, P. Eng (e-mail)