

**City of Winnipeg**  
**Water and Waste Department**  
**North End Water Pollution Control Centre Monitoring Data**  
**August 2016**

Licence 2684 RRR	File # 1071.10	Final Effluent 24 Hour Composite							Final Effluent Grab Sample				
Date	Raw Sewage Daily Flow	TSS	BOD5	cBOD5	Ammonia	Ortho Phosphorus	Total Phosphorus	Total Nitrogen	Temp. (°C)	pH (units)	Fecal Coliform	E.Coli	
	ML**	(mg/L)	(mg/L)	(mg/L)	(kg NH3-N/day)	(mg/L-P)	(mg/L-P)*	(mg/L-N)*			(°C)	MPN/100 mL	
1-Aug-16	350.7	43	46	20	1,193	1.97	3.2	23.4	20.2	6.37	(>110,000)	(>110,000)	
2-Aug-16	244.6	13	10	6	nr	1.46	3.2	23.4	20.0	6.70	430	240	
3-Aug-16	194.3	16	12	6	1,170	2.50	3.2	23.3	19.8	6.63	2,100	2,100	
4-Aug-16	200.9	8	9	6	1,169	2.20	3.2	23.4	20.1	6.64	9,300	4,300	
5-Aug-16	167.5	11	9	6	1,196	2.83	3.2	23.3	20.2	6.59	74	43	
6-Aug-16	157.0	12	8	5	1,020	3.27	3.2	23.2	20.5	6.50	240	240	
7-Aug-16	150.6	12	11	6	839	3.55	3.2	23.0	20.0	6.45	74	9	
8-Aug-16	159.0	10	10	6	897	3.35	3.2	22.8	19.9	6.47	21	15	
9-Aug-16	157.2	16	15	7	1,267	3.62	3.3	22.8	19.9	6.53	23	9	
10-Aug-16	155.4	16	11	6	1,787	3.87	3.3	22.9	20.2	6.44	15	7	
11-Aug-16	156.4	12	13	6	1,861	4.03	3.4	23.4	20.5	6.42	240	240	
12-Aug-16	153.3	12	10	6	1,870	3.67	3.5	24.0	21.1	6.47	74	74	
13-Aug-16	134.8	13	12	7	1,645	3.74	3.5	24.3	21.0	6.56	140	43	
14-Aug-16	139.7	16	13	7	1,593	4.12	3.6	24.7	20.4	6.46	23	23	
15-Aug-16	236.8	25	39	22	2,368	2.89	3.6	24.8	20.4	6.35	43	15	
16-Aug-16	236.5	12	10	6	1,391	1.97	3.5	24.7	20.9	6.48	2,400	930	
17-Aug-16	170.5	50	41	23	1,995	2.72	3.5	24.8	21.0	6.43	430	240	
18-Aug-16	<b>445.5</b>	13	12	7	1,769	1.34	3.4	24.3	20.7	6.60	(930)	(930)	
19-Aug-16	197.1	8	7	5	1,665	2.23	3.4	24.5	20.9	6.68	150	93	
20-Aug-16	168.1	10	8	6	1,765	3.07	3.5	24.9	20.8	6.60	150	150	
21-Aug-16	152.1	12	8	5	1,749	3.47	3.5	25.2	20.2	6.60	240	240	
22-Aug-16	158.8	11	10	6	1,683	3.36	3.6	25.7	20.1	6.57	43	15	
23-Aug-16	156.3	11	11	6	1,813	3.64	3.6	26.3	20.4	6.52	74	<3	
24-Aug-16	155.6	15	12	7	2,318	3.69	3.7	26.9	20.5	6.64	240	240	
25-Aug-16	209.3	14	15	8	2,554	2.99	3.7	27.2	19.9	6.89	140	93	
26-Aug-16	150.1	4	9	6	1,997	3.65	3.7	27.7	20.3	6.57	9,300	9	
27-Aug-16	133.0	12	9	5	2,021	4.22	3.7	28.2	21.4	6.66	43	43	
28-Aug-16	139.1	10	11	4	1,975	4.18	3.7	28.6	20.3	6.56	43	7	
29-Aug-16	142.1	10	10	5	1,989	4.19	3.7	29.0	20.3	6.50	93	11	
30-Aug-16	139.4	11	11	5	2,119	4.73	3.8	29.3	20.4	6.59	150	74	
31-Aug-16	142.4	9	14	6	2,820	4.52	3.8	30.1	20.5	6.63	240	93	
<b>Max:</b>	445.5												
<b>Min:</b>	133.0												
<b>Average:</b>	<b>182.4</b>	<b>14</b>	<b>14</b>	<b>7</b>	<b>1,716</b>	<b>3.26</b>			<b>20</b>	<b>6.55</b>			
<b>Total Flow:</b>	<b>5654.0</b>										<b>159</b>	<b>60</b>	
<b>Geo.Mean:</b>													

**Notes:**

- (1) Effluent ammonia load based upon Raw Sewage flows and Final NH3-N concentrations
- (2) nr - not recorded or no result; na - not analyzed; ns - no sample
- (3) Where value is expressed as less than (<), the value is halved and used in the calculations
- (4) \* = 30 day rolling average
- (5)\*\* Flow, highlighted in bold, in excess of 380 ML/D per clause 26 of Licence 2684RRR

- (6) Bracketed Coliform results not used in the Geometric Mean calculation
- (7) Raw wastewater flows in excess of 400 ML/D will by-pass the secondary process and flows in excess of 675 ML/D will cause raw sewage to by-pass the plant