

City of Winnipeg
Water and Waste Department
West End Water Pollution Control Centre Monitoring Data

March 2012

Date	Raw Sewage	Final Effluent 24 Hour Composite									Final Effluent Grab Sample			
		TSS	cBOD5	Ammonia		Ortho Phosphorus	Total Phosphorus		Total Nitrogen		Temp.	pH	Fecal Coliform	E.Coli
	Daily Flow	ML	(mg/L)	(mg/L)	(mg/L-N)	(kg NH3-N/day)	(mg/L-P)	(mg/L-P)	(mg/L-P)*	(mg/L-N)	(mg/L-N)*	(°C)	(units)	MPN/100 mL
1-Mar-12	19.6	11	7	1.48	29	0.26	0.5	0.5	6	6	0	7.33	43	43
2-Mar-12	19.8	13	7	1.47	29	0.25	0.5	0.5	6	6	1	7.35	23	23
3-Mar-12	19.8	7	7	1.68	33	0.26	0.5	0.5	5	6	0	7.30	21	15
4-Mar-12	23.1	10	7	1.49	34	0.23	0.5	0.5	6	6	0	7.37	23	9
5-Mar-12	20.2	8	7	1.58	32	0.27	0.5	0.5	6	6	1	7.38	150	93
6-Mar-12	19.8	8	7	2.28	45	0.27	0.5	0.5	6	6	0	7.29	230	43
7-Mar-12	20.0	8	7	1.79	36	0.27	0.5	0.5	6	6	0	7.28	93	43
8-Mar-12	20.1	6	6	1.97	40	0.33	0.5	0.5	7	6	0	7.21	230	93
9-Mar-12	20.2	7	6	2.03	41	0.29	0.5	0.5	6	6	1	7.28	93	75
10-Mar-12	23.1	9	8	2.16	50	0.27	0.6	0.5	6	6	0	7.38	23	4
11-Mar-12	29.2	9	9	1.95	57	0.26	0.5	0.5	6	6	1	7.41	23	9
12-Mar-12	39.6	8	8	1.66	66	0.25	0.5	0.5	6	6	1	7.40	9	9
13-Mar-12	32.6	11	10	1.53	50	0.21	0.5	0.5	6	6	1	7.37	9	4
14-Mar-12	32.2	16	10	1.28	41	0.19	0.6	0.5	7	6	1	7.50	9	4
15-Mar-12	25.1	19	11	1.14	29	0.16	0.5	0.5	7	6	2	7.50	4	4
16-Mar-12	25.7	21	10	0.93	24	0.13	0.5	0.5	6	6	3	7.78	43	15
17-Mar-12	26.7	29	11	0.72	19	0.10	0.5	0.5	5	6	2	7.95	<3	<3
18-Mar-12	26.0	24	11	0.76	20	0.07	0.4	0.5	4	6	3	8.29	<3	<3
19-Mar-12	24.8	21	9	0.37	9	0.06	0.5	0.5	5	6	5	8.44	4	4
20-Mar-12	32.9	17	8	0.29	10	0.07	0.4	0.5	4	6	3	8.48	93	93
21-Mar-12	23.6	26	7	0.18	4	0.05	0.4	0.5	4	6	3	8.56	2,300	2,300
22-Mar-12	22.3	26	9	0.09	2	0.04	0.3	0.5	3	6	4	8.94	<3	<3
23-Mar-12	21.8	28	9	0.02	<1	0.02	0.4	0.5	4	5	7	9.06	4	4
24-Mar-12	28.9	18	9	0.03	1	0.02	0.4	0.5	2	5	6	9.02	9	9
25-Mar-12	24.5	41	12	<0.02	<1	0.01	0.5	0.5	3	5	4	9.31	9	9
26-Mar-12	22.7	50	12	<0.02	<1	0.02	0.5	0.5	3	5	5	9.46	23	4
27-Mar-12	30.2	48	11	0.43	13	0.04	0.5	0.5	3	5	4	9.35	9	9
28-Mar-12	28.2	52	10	<0.02	<1	0.02	0.5	0.5	3	5	3	9.53	16	15
29-Mar-12	30.9	52	10	<0.02	<1	0.02	0.6	0.5	3	5	4	9.61	9	4
30-Mar-12	36.8	22	10	0.02	1	0.06	0.6	0.5	3	5	5	9.58	4	4
31-Mar-12	27.7	61	11	0.13	4	0.07	0.7	0.5	3	5	4	9.58	<3	<3
Max:	39.6													
Min:	19.6													
Average:	25.7	22	9	0.95	23	0.15	0.5		5		2	8.17		
Geo.Mean:												3	2	

Notes:

(1) * = 30 day rolling average

(2) Effluent ammonia load based upon Raw Sewage flows and Final Cell NH3-N concentrations

(3) nr - not recorded or no result; na - not analyzed; ns - no sample

(4) Final Effluent flow data unavailable

(5) Where < values are reported 50% of the MDL is used for calculated results

(6) Licence No. 2669 E RR

(7) Total Nitrogen results are calculated from TKN and nitrate values.