



Kale Black, Sr. Drinking Water Officer  
Office of Drinking Water, Manitoba Sustainable Development  
309 – 25 Tupper Street North  
Portage La Prairie, MB R1N 3K1

**May 7, 2025**

**RE: CORRECTIVE ACTION REPORT FOR WINNIPEG PUBLIC WATER SYSTEM, 252.00**

**Incident No:** CAR-08-2025-ESD

**Reported to ODW:** May 1, 2025

**Reported by:** Courtney Diduck, Analytical Services Branch Head

**Approved by:** Courtney Diduck, Analytical Services Branch Head

**Incident Date:** April 30, 2025

**Incident Location:** Winnipeg 3-Dist (SE06)

**Incident Type:** Low Positive Total Coliform (<10 per100mL), 3 MR 41/2007

**Description and Corrective Actions:**

Environmental Standards:

IMMEDIATELY: Contacted the ODW and re-sampled original location for bacteria, turbidity, free/total chlorine, and temperature. Monitoring was terminated after two consecutive sets of re-samples taken 24 hours apart tested negative for bacteria.

**Test Results:** See attached

**Reference No:** Job 2206

**EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER IN SITUATIONS REQUIRING IMMEDIATE REPORTING**

N:\Environmental Standards\Analytical Services\Government Agencies\Office of Drinking Water\Corrective Action Reports



Water and Waste  
Eaux et déchets

Sample Name	Sample Number	Date Sampled	E Coli (MPNU/100mL)	Total Coliform (MPNU/100mL)	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Turbidity-field (ntu)	Temperature (°C)	Time Sampled (hrs)
SE06	747935	30-Apr-25	0	1	0.97	1.14	0.21	5.5	12:30
SE06_Resample 1	748905	1-May-25	0	0	0.97	1.09	0.14	5.2	15:00
SE06_Resample 1 (Duplicate)	748906	1-May-25	0	0	0.95	1.06	0.17	5.1	15:05
SE06_Resample 2	748907	2-May-25	0	0	1.05	1.25	0.13	6.3	14:48
SE06_Resample 1 (Duplicate)	748908	2-May-25	0	0	1.03	1.27	0.13	6.3	14:51

Notes/Comments:

1. All microbiological tests performed by contract laboratory.
2. ol - autosampler or process offline
3. na - not applicable or not analyzed