



Water and Waste Department • Service des eaux et des déchets

August 7, 2014

Our File: 040-18-18-55-00

Melanie Betsill
Office of Drinking Water
Manitoba Conservation and Water Stewardship
1007 Century Street
Winnipeg, Manitoba R3H 0W4

Dear Ms. Betsill:

**RE: JULY 2014 WATER QUALITY COMPLIANCE
SUBMISSION FOR THE CITY OF WINNIPEG WATER SUPPLY SYSTEM**

Please find attached on-line and grab turbidity summary reports, on-line and grab chlorine summary reports and the UV summary report for the Water Treatment Plant for July 2014.

The July on-line and grab sampling turbidity reports include results obtained for the Water Treatment Plant raw water and the eight filters. The turbidity results for the effluent from the filters are in compliance with the licence requirements.

The July on-line and grab sampling chlorine reports include results obtained for the Deacon Boaster Pumping Station at the Water Treatment Plant. The free chlorine results at the Water Treatment Plant have met the licence requirements.

The UV submission includes the summary report for July 2014 in accordance with Section 4.13, Table 2 of the Operating Licence. The UV licence requirement has been met for July.

Please let me know of any concerns or questions respecting this submission. I may be reached by telephone at 204-986-4807 or by e-mail at kkjartanson@winnipeg.ca.

Thanks for your ongoing cooperation and understanding in this matter.

Yours sincerely,

Original signed by:

K.J.T. Kjartanson, P.Eng.
Manager of Environmental Standards
KJTK:rg
Attachments

c:(e-mail)

Dr. L. Richards, Winnipeg Regional Health Authority	D.P. Sacher, P.Eng.
Dr. H. Chang, Winnipeg Regional Health Authority	T. Shanks, P.Eng.
Dr. S. Roberecki, Manitoba Health	S. Fletcher
G. Patton, P.Eng.	
A. J. Weremy, P.Eng.	



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT TURBIDITY GRAB MONITORING REPORT

Water System Code: 252.00	Turbidity (NTU)									
Licence No. PWS-09-412 A	Date	Raw Water	Filter 1	Filter 2	Filter 3	Filter 4	Filter 5	Filter 6	Filter 7	Filter 8
	01-Jul-2014	1.26	0.07	0.08	0.07	0.06	<0.05	0.10	0.06	0.05
	02-Jul-2014	0.98	0.11	0.06	0.07	0.07	0.08	0.06	0.06	0.07
	03-Jul-2014	0.87	0.09	0.09	0.13	0.08	0.08	0.11	0.12	0.08
	04-Jul-2014	0.80	0.13	0.12	0.16	0.10	0.10	0.10	0.09	0.09
	05-Jul-2014	NS	NS	NS	NS	NS	NS	NS	NS	NS
	06-Jul-2014	NS	NS	NS	NS	NS	NS	NS	NS	NS
	07-Jul-2014	0.86	0.09	0.09	0.12	0.09	0.08	0.10	0.07	0.09
	08-Jul-2014	0.75	0.13	0.14	0.10	0.11	0.10	0.10	0.09	0.10
	09-Jul-2014	0.73	0.12	0.10	0.12	0.12	0.13	0.11	0.10	0.16
	10-Jul-2014	0.85	0.14	0.13	0.16	0.21	0.11	0.14	0.13	0.12
	11-Jul-2014	0.75	0.09	0.11	0.09	0.07	0.10	0.14	0.08	0.09
	12-Jul-2014	NS	NS	NS	NS	NS	NS	NS	NS	NS
	13-Jul-2014	NS	NS	NS	NS	NS	NS	NS	NS	NS
	14-Jul-2014	0.94	0.07	0.06	0.06	0.09	0.05	0.06	0.07	0.14
	15-Jul-2014	1.19	0.08	0.08	0.11	0.08	0.09	0.12	0.15	0.09
	16-Jul-2014	1.02	0.12	0.10	0.15	0.10	0.09	0.08	0.09	0.10
	17-Jul-2014	0.99	0.14	0.13	0.10	0.09	0.09	0.11	0.09	0.12
	18-Jul-2014	0.89	0.09	0.09	0.12	0.14	0.07	0.09	0.10	0.09
	19-Jul-2014	NS	NS	NS	NS	NS	NS	NS	NS	NS
	20-Jul-2014	NS	NS	NS	NS	NS	NS	NS	NS	NS
	21-Jul-2014	0.91	0.10	0.10	0.09	0.08	0.06	0.06	0.06	0.07
	22-Jul-2014	1.01	0.08	0.07	0.06	0.09	0.07	0.06	0.07	0.08
	23-Jul-2014	1.01	0.07	0.06	0.09	0.10	0.07	0.08	0.10	0.09
	24-Jul-2014	0.79	0.09	0.08	0.11	0.10	0.09	0.13	0.11	0.15
	25-Jul-2014	0.99	0.12	0.10	0.10	0.14	0.08	0.08	0.08	0.07
	26-Jul-2014	NS	NS	NS	NS	NS	NS	NS	NS	NS
	27-Jul-2014	NS	NS	NS	NS	NS	NS	NS	NS	NS
	28-Jul-2014	1.15	0.07	0.09	0.12	0.08	0.07	0.05	0.07	0.07
	29-Jul-2014	1.08	0.11	0.06	0.07	0.07	0.05	0.07	0.06	0.08
	30-Jul-2014	1.06	0.07	0.07	0.07	0.09	0.06	0.07	0.06	0.07
	31-Jul-2014	0.93	0.07	0.07	0.11	0.07	0.08	0.05	<0.05	0.06
Total number of measurements taken, A:		23	23	23	23	23	23	23	23	23
Turbidity Standard for Monitoring Location (NTU):		0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30	0.30
Number of measurements meeting standard, B:		23	23	23	23	23	23	23	23	23
Compliance with Turbidity Standard, C= B/A X 100%:		100%	100%	100%	100%	100%	100%	100%	100%	100%

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

Report Compiled By: J. Jones

Approved in LIMS By: S. Fletcher/ A. Vanderstel



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: **252.00**
Licence Number: **PWS-09-412 A**

WATER TREATMENT PLANT TURBIDITY ON-LINE MONITORING REPORT

July 2014 Turbidity (NTU)

Date	Raw		Filter #1		Filter #2		Filter #3		Filter #4		Filter #5		Filter #6		Filter #7		Filter #8	
	Avg	Avg	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max	Avg	Max
1/07/2014	1.05	0.01	0.01		0.03	0.09	0.02	0.28	0.02	0.04	0.03	0.08	0.04	0.11	0.01	0.04	0.01	0.01
2/07/2014	1.12	0.00	0.01		0.01	0.04	0.02	0.16	0.02	0.15	0.02	0.17	0.03	0.15	0.01	0.08	0.00	0.06
3/07/2014	1.12	0.01	0.01		0.05	0.10	0.04	0.12	0.03	0.12	0.03	0.06	0.05	0.13	0.02	0.08	0.00	0.07
4/07/2014	1.06	0.01	0.02		0.04	0.12	0.04	0.14	0.04	0.06	0.04	0.11	0.05	0.15	0.02	0.03	0.01	0.04
5/07/2014	1.04	0.01	0.02		0.04	0.11	0.03	0.06	0.04	0.13	0.03	0.11	0.06	0.09	0.03	0.10	0.00	0.06
6/07/2014	1.08	0.01	0.01		0.04	0.07	0.05	0.25	0.03	0.11	0.03	0.11	0.06	0.12	0.02	0.08	0.01	0.05
7/07/2014	1.09	0.01	0.02		0.04	0.11	0.03	0.12	0.03	0.10	0.04	0.06	0.05	0.14	0.02	0.08	0.00	0.01
8/07/2014	1.05	0.01	0.02		0.05	0.11	0.05	0.17	0.05	0.07	0.05	0.10	0.05	0.19	0.03	0.05	0.01	0.04
9/07/2014	1.01	0.01	0.04		0.05	0.16	0.05	0.08	0.05	0.13	0.05	0.11	0.07	0.12	0.05	0.12	0.01	0.07
10/07/2014	1.03	0.01	0.01		0.08	0.10	0.08	0.18	0.05	0.16	0.05	0.14	0.07	0.18	0.03	0.13	0.01	0.09
11/07/2014	1.10	0.01	0.03		0.05	0.16	0.04	0.16	0.03	0.10	0.04	0.11	0.04	0.17	0.01	0.04	0.01	0.02
12/07/2014	0.74	0.01	0.01		0.04	0.12	0.03	0.13	0.03	0.06	0.02	0.05	0.03	0.06	0.01	0.03	0.01	0.05
13/07/2014	0.96	0.01	0.01		0.04	0.13	0.03	0.12	0.04	0.07	0.03	0.11	0.04	0.06	0.01	0.06	0.00	0.04
14/07/2014	1.13	0.01	0.01		0.04	0.07	0.04	0.07	0.03	0.14	0.03	0.10	0.06	0.16	0.01	0.10	0.01	0.07
15/07/2014	1.14	0.01	0.01		0.06	0.13	0.05	0.15	0.04	0.13	0.03	0.06	0.05	0.15	0.02	0.10	0.01	0.07
16/07/2014	1.06	0.01	0.01		0.05	0.12	0.04	0.16	0.04	0.06	0.05	0.12	0.05	0.15	0.02	0.10	0.01	0.02
17/07/2014	0.88	0.01	0.01		0.05	0.15	0.04	0.17	0.05	0.12	0.02	0.05	0.05	0.08	0.02	0.05	0.01	0.07
18/07/2014	0.66	0.01	0.01		0.05	0.08	0.06	0.11	0.04	0.12	0.04	0.11	0.05	0.13	0.01	0.08	0.01	0.04
19/07/2014	0.77	0.01	0.01		0.05	0.13	0.04	0.13	0.03	0.11	0.03	0.09	0.04	0.13	0.01	0.07	0.01	0.04
20/07/2014	0.74	0.01	0.01		0.05	0.12	0.04	0.16	0.03	0.06	0.03	0.11	0.04	0.12	0.01	0.06	0.01	0.01
21/07/2014	0.82	0.01	0.09		0.04	0.12	0.04	0.13	0.04	0.10	0.03	0.09	0.04	0.11	0.01	0.02	0.01	0.04
22/07/2014	0.80	0.02	0.10		0.03	0.06	0.03	0.12	0.03	0.10	0.03	0.05	0.04	0.11	0.02	0.06	0.01	0.03
23/07/2014	0.79	0.02	0.10		0.00	0.01	0.05	0.08	0.03	0.09	0.04	0.10	0.03	0.10	0.02	0.09	0.00	0.01
24/07/2014	0.78	0.04	0.06		0.01	0.05	0.05	0.12	0.03	0.10	0.03	0.06	0.03	0.08	0.03	0.08	0.00	0.02
25/07/2014	1.16	0.02	0.10		0.01	0.14	0.04	0.15	0.04	0.07	0.02	0.09	0.02	0.08	0.02	0.05	0.00	0.01
26/07/2014	1.01	0.04	0.10		0.02	0.07	0.06	0.14	0.05	0.09	0.05	0.08	0.05	0.08	0.03	0.07	0.01	0.01
27/07/2014	1.14	0.03	0.09		0.02	0.04	0.08	0.11	0.04	0.09	0.05	0.09	0.04	0.08	0.03	0.07	0.01	0.01
28/07/2014	1.22	0.04	0.09		0.02	0.07	0.06	0.18	0.04	0.06	0.04	0.11	0.03	0.11	0.02	0.03	0.01	0.01
29/07/2014	1.21	0.02	0.11		0.02	0.10	0.06	0.18	0.04	0.13	0.03	0.06	0.03	0.05	0.03	0.09	0.00	0.02
30/07/2014	1.13	0.02	0.09		0.02	0.04	0.09	0.11	0.03	0.11	0.05	0.11	0.03	0.09	0.02	0.09	0.00	0.01
31/07/2014	1.13	0.03	0.06		0.04	0.10	0.06	0.30	0.03	0.05	0.03	0.10	0.02	0.08	0.01	0.08	0.01	0.01

Total Number of Measurements Taken, A: 13513 13683 13789 11830 14434 14458 13212 14200
Turbidity Standard for Monitoring Location (NTU): 0.30 0.30 0.30 0.30 0.30 0.30 0.30 0.30
Number of Measurements Meeting Standard, B: 13513 13683 13789 11830 14434 14458 13212 14200
Compliance with Turbidity Standard, C = B/A X 100%: 100.00% 100.00% 100.00% 100.00% 100.00% 100.00% 100.00% 100.00%

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Turbidity\2014\07-July

Submitted By (Print) M.Szmon for A.Weremy

Signature Original signed by M.Szmon



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENVIRONMENTAL STANDARDS DIVISION

WATER TREATMENT PLANT CHLORINE GRAB MONITORING REPORT				
Water System Code: 252.00	Deacon Booster Pumping Station Branch 1		Deacon Booster Pumping Station Branch 2	
Licence No. PWS-09-412 A	Date	Free Chlorine (mg/L)	Total Chlorine (mg/L)	Free Chlorine (mg/L)
	01-Jul-2014	1.13	1.29	1.11
	02-Jul-2014	1.18	1.36	1.17
	03-Jul-2014	1.24	1.45	1.15
	04-Jul-2014	1.27	1.42	1.12
	05-Jul-2014	NS	NS	NS
	06-Jul-2014	NS	NS	NS
	07-Jul-2014	1.14	1.31	1.09
	08-Jul-2014	1.17	1.28	1.05
	09-Jul-2014	1.22	1.36	1.19
	10-Jul-2014	1.30	1.42	1.20
	11-Jul-2014	1.34	1.46	1.27
	12-Jul-2014	NS	NS	NS
	13-Jul-2014	NS	NS	NS
	14-Jul-2014	1.51	1.66	1.49
	15-Jul-2014	1.45	1.58	1.38
	16-Jul-2014	1.33	1.46	1.34
	17-Jul-2014	1.26	1.45	1.23
	18-Jul-2014	1.30	1.40	1.29
	19-Jul-2014	NS	NS	NS
	20-Jul-2014	NS	NS	NS
	21-Jul-2014	1.05	1.24	1.20
	22-Jul-2014	1.19	1.32	1.18
	23-Jul-2014	1.31	1.44	1.33
	24-Jul-2014	1.27	1.40	1.26
	25-Jul-2014	1.22	1.34	1.23
	26-Jul-2014	NS	NS	NS
	27-Jul-2014	NS	NS	NS
	28-Jul-2014	1.38	1.47	1.35
	29-Jul-2014	1.49	1.62	1.40
	30-Jul-2014	1.34	1.49	1.29
	31-Jul-2014	1.46	1.59	1.46
Total number of measurements taken, A:	23		23	
Chlorine Standard for Monitoring Location (mg/L):	0.50		0.50	
Number of measurements meeting standard, B:	23		23	
Compliance with Chlorine Standard, C= B/A X 100%:	100%		100%	

NS: No Sample NA: Not Analyzed OL: Off-Line

Comments:

Report Compiled By: _____ J. Jones

Approved in LIMS By: _____ S. Fletcher/ A. Vanderstel

**City of Winnipeg**

Water and Waste Department

Water Services

WATER TREATMENT PLANT FREE CHLORINE ON-LINE MONITORING REPORT
Deacon Booster Pumping StationWater System Code: **252.00**Licence Number: **PWS-09-412 A**

Report Created: 01 August 2014

Report Period: July 2014

Date	BRANCH 1 [mg/L]		BRANCH 2 [mg/L]	
	Average	Minimum	Average	Minimum
01/07/2014	1.07	0.97	1.14	1.02
02/07/2014	0.99	0.88	1.03	0.93
03/07/2014	1.17	0.96	1.11	0.99
04/07/2014	1.21	1.10	1.10	1.03
05/07/2014	1.15	1.00	1.03	0.87
06/07/2014	0.99	0.89	0.95	0.88
07/07/2014	1.04	0.96	1.03	0.97
08/07/2014	1.14	0.93	1.10	0.92
09/07/2014	1.20	1.09	1.16	1.05
10/07/2014	1.18	1.07	1.14	1.08
11/07/2014	1.20	1.14	1.19	1.07
12/07/2014	1.24	1.14	1.28	1.16
13/07/2014	1.32	1.25	1.30	1.17
14/07/2014	1.33	1.25	1.28	1.18
15/07/2014	1.34	1.24	1.30	1.18
16/07/2014	1.22	1.12	1.24	1.10
17/07/2014	1.22	1.13	1.27	1.10
18/07/2014	1.21	1.15	1.21	1.07
19/07/2014	1.16	1.10	1.13	1.04
20/07/2014	1.14	1.03	1.15	1.03
21/07/2014	1.17	1.08	1.20	1.06
22/07/2014	1.24	1.13	1.33	1.20
23/07/2014	1.27	1.17	1.32	1.20
24/07/2014	1.22	1.14	1.20	1.07
25/07/2014	1.14	0.85	1.07	0.73
26/07/2014	1.32	1.11	1.31	1.09
27/07/2014	1.33	1.22	1.25	1.13
28/07/2014	1.30	1.12	1.30	1.13
29/07/2014	1.44	1.32	1.36	1.21
30/07/2014	1.32	1.24	1.24	1.11
31/07/2014	1.40	1.30	1.43	1.27

Total Number of Measurements, A: **21489** 21488Minimum Free Chlorine Standard: **0.50** 0.50Number of Measurements Meeting Standard, B: **21489** 21488COMPLIANCE, C = B/A X 100%: **100** 100

File Path: N:\Water Treatment Branch\Administration\Reports\Regulatory Submissions\Chlorine\2014\07-July

Submitted By (Print): M.Szmon for A.WeremySignature: Original signed by M.Szmon



CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
WATER SERVICES

Water System Code: 252.00
Licence Number: PWS-09-412 A

WATER TREATMENT PLANT UV REPORT

Report Period: July 2014

Report Created: Friday, August 01, 2014

Date	Transmittance %	UVR-D100A				UVR-D200A				UVR-D300A				UVR-D400A				UVR-D500A				UVR-D600A				Total Water Volume [ML]				% Volume Treated To Dose
		Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				Water Volume [ML]				
	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total	Untreated	Below	To	Total		
1/07/2014	96.64	0.00	0.00	84.99	84.99	0.00	0.00	0.00	0.00	0.00	0.00	18.64	18.64	0.00	0.00	46.16	46.16	0.00	0.00	0.00	0.00	0.00	0.00	85.01	85.01	0.00	0.00	234.79	234.79	100.00
2/07/2014	95.70	0.03	0.03	23.31	23.36	0.00	0.00	0.62	0.62	0.00	0.00	0.00	0.00	0.04	0.04	40.55	40.64	0.00	0.00	15.17	15.17	0.00	0.00	47.69	47.69	0.07	0.07	127.34	127.48	99.89
3/07/2014	96.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	83.80	83.80	0.00	0.00	60.46	60.46	0.00	0.06	84.95	85.01	0.00	0.06	229.21	229.27	99.97
4/07/2014	96.55	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	84.54	84.54	0.00	0.00	67.57	67.57	0.00	0.00	84.75	84.75	0.00	0.00	236.86	236.86	100.00
5/07/2014	96.56	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	84.66	84.66	0.00	0.00	70.57	70.57	0.00	0.00	85.29	85.29	0.00	0.00	240.52	240.52	100.00
6/07/2014	96.56	0.00	0.00	0.00	0.00	0.00	0.00	64.34	64.34	0.00	0.00	0.00	0.00	0.00	0.00	59.94	59.94	0.00	0.00	46.67	46.67	0.00	0.00	75.72	75.72	0.00	0.00	246.67	246.67	100.00
7/07/2014	96.62	0.09	0.09	23.05	23.23	0.00	0.00	83.59	83.59	0.00	0.00	0.00	0.00	0.06	0.06	31.35	31.46	0.00	0.00	38.42	38.42	0.00	0.00	71.49	71.49	0.15	0.15	247.89	248.19	99.88
8/07/2014	96.42	0.00	0.00	58.70	58.70	0.00	0.00	81.96	81.96	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	38.14	38.14	0.00	0.00	70.55	70.55	0.00	0.00	249.36	249.36	100.00
9/07/2014	96.41	0.00	0.00	36.09	36.09	0.00	0.00	84.37	84.37	0.00	0.00	22.61	22.61	0.00	0.00	0.00	0.00	0.00	0.00	39.05	39.05	0.00	0.00	72.64	72.64	0.00	0.00	254.76	254.76	100.00
10/07/2014	96.14	0.00	0.00	0.00	0.00	0.00	0.00	84.69	84.69	0.00	0.00	44.95	44.95	0.00	0.00	33.42	33.42	0.00	0.00	12.00	12.00	0.00	0.00	81.47	81.47	0.00	0.00	256.53	256.53	100.00
11/07/2014	96.57	0.00	0.00	0.00	0.00	0.00	0.00	85.01	85.01	0.00	0.00	39.73	39.73	0.00	0.00	48.24	48.24	0.00	0.00	0.00	0.00	0.00	0.00	85.01	85.01	0.00	0.00	257.99	257.99	100.00
12/07/2014	96.59	0.00	0.00	0.00	0.00	0.00	0.00	85.00	85.00	0.00	0.00	39.54	39.54	0.00	0.00	48.41	48.41	0.00	0.00	0.00	0.00	0.00	0.00	84.98	84.98	0.00	0.00	257.94	257.94	100.00
13/07/2014	96.40	0.00	0.00	0.00	0.00	0.00	0.00	85.02	85.02	0.00	0.00	32.90	32.90	0.00	0.00	40.75	40.75	0.00	0.00	0.00	0.00	0.00	0.00	84.99	84.99	0.00	0.00	243.67	243.67	100.00
14/07/2014	95.89	0.00	0.00	0.00	0.00	0.00	0.00	85.01	85.01	0.00	0.00	31.17	31.17	0.00	0.00	38.79	38.79	0.00	0.00	0.00	0.00	0.00	0.00	85.03	85.03	0.00	0.00	239.99	239.99	100.00
15/07/2014	96.32	0.00	0.00	0.00	0.00	0.00	0.00	85.00	85.00	0.00	0.00	31.32	31.32	0.00	0.00	38.68	38.68	0.00	0.00	0.00	0.00	0.00	0.00	84.97	84.97	0.00	0.00	239.97	239.97	100.00
16/07/2014	96.27	0.00	0.00	0.00	0.00	0.00	0.00	85.01	85.01	0.00	0.00	59.31	59.31	0.00	0.00	70.18	70.18	0.00	0.00	0.00	0.00	0.00	0.00	27.17	27.17	0.00	0.00	241.68	241.68	100.00
17/07/2014	96.21	0.00	0.00	34.61	34.61	0.00	0.00	77.99	77.99	0.00	0.00	36.29	36.29	0.00	0.00	37.36	37.36	0.00	0.00	15.79	15.79	0.00	0.00	44.13	44.13	0.00	0.00	246.17	246.17	100.00
18/07/2014	96.46	0.00	0.00	49.80	49.80	0.00	0.00	75.55	75.55	0.00	0.00	42.79	42.79	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	80.25	80.25	0.00	0.00	248.39	248.39	100.00
19/07/2014	96.53	0.00	0.00	49.44	49.44	0.00	0.00	74.14	74.14	0.00	0.00	41.96	41.96	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	79.41	79.41	0.00	0.00	244.96	244.96	100.00
20/07/2014	96.40	0.00	0.00	48.14	48.14	0.00	0.00	71.71	71.71	0.00	0.00	40.81	40.81	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	78.36	78.36	0.00	0.00	239.02	239.02	100.00
21/07/2014	96.54	0.00	0.00	48.91	48.91	0.00	0.00	72.75	72.75	0.00	0.00	41.16	41.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	78.83	78.83	0.00	0.00	241.64	241.64	100.00
22/07/2014	96.46	0.00	0.00	49.95	49.95	0.00	0.00	74.64	74.64	0.00	0.00	42.27	42.27	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	80.02	80.02	0.00	0.00	246.87	246.87	100.00
23/07/2014	96.39	0.00	0.00	50.24	50.24	0.00	0.00	75.19	75.19	0.00	0.00	42.96	42.96	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	80.49	80.49	0.00	0.00	248.89	248.89	100.00
24/07/2014	96.33	0.00	0.00	54.51	54.51	0.00	0.00	78.63	78.63	0.01	0.24	20.28	20.52	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	75.28	75.28	0.01	0.24	248.51	248.76	99.90
25/07/2014	95.96	0.00	0.00	42.08	42.08	0.00	0.00	63.25	63.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.04	29.61	29.66	0.00	0.00	52.27	52.27	0.00	0.04	187.21	187.25	99.98
26/07/2014	96.25	0.00	0.00	59.93	59.93	0.00	0.00	84.96	84.96	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	40.15	40.15	0.00	0.00	74.46	74.46	0.00	0.00	259.50	259.50	100.00
27/07/2014	96.48	0.00	0.00	51.04	51.04	0.00	0.00	81.78	81.78	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	41.15	41.15	0.00	0.00	71.77	71.77	0.00	0.00	245.74	245.74	100.00
28/07/2014	96.41	0.00	0.00	0.00	0.00	0.00	0.00	85.00	85.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	57.75	57.75	0.00	0.00	85.05	85.05	0.00	0.00	227.80	227.80	100.00
29/07/2014	96.40	0.00	0.00	0.00	0.00	0.00	0.00	84.76	84.76	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	54.98	54.98	0.00	0.00	85.26	85.26	0.00	0.00	224.99	224.99	100.00
30/07/2014	96.44	0.00	0.00	0.00	0.00	0.00	0.00	84.84	84.84	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	62.11	62.11	0.00	0.06	85.09	85.15	0.00	0.06	232.03	232.09	99.97
31/07/2014	96.56	0.00	0.00	0.00	0.00	0.00	0.00	85.01	85.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	66.31	66.31	0.00	0.51	83.12	83.63	0.00	0.51	234.44	234.95	99.78

Water Volume [%]:

Untreated: 0.00 %
Below Dose: 0.02 %
To Dose: 99.98 %

Submitted By (Print): M.Szmon for A.Weremy



Water and Waste Department • Service des eaux et des déchets

Wednesday, February 18, 2015

Our Incident/Report No: 04-2014

LIMS Reference No: 39689

Ms. Melanie Betsill
Drinking Water Officer
Manitoba Water Stewardship, Office of Drinking Water
1007 Century Street
Winnipeg MB R3H 0W4

RE: CORRECTIVE ACTION REPORT

WATER SYSTEM	Winnipeg Public Water System
WATER SYSTEM CODE	252.00
LOCATION OF NON-COMPLIANT INCIDENT	Winnipeg 4-Dist WC02
OPERATOR IN CHARGE	NA
INCIDENT REPORTED BY	Gerry Levesque, acting Supervisor of Analytical Services Branch
TYPE OF NON-COMPLIANT INCIDENT	Low positive Total Coliform (<10 per100mL), 3 MR 41/2007
INCIDENT DATE	July 7, 2014
DESCRIPTION OF CORRECTIVE ACTIONS	AS SOON AS POSSIBLE: Re-sampled original location, also tested for turbidity, free/total chlorine, temperature and contacted the ODW.
TEST RESULTS	See Attached

NOTES/COMMENTS:

1. All microbiological tests performed by contract laboratory.
2. UP/DOWN STREAM testing performed when EC is >0 /100mL, TC is >10 /100mL or when resample/consecutive sample is positive for EC or TC or as directed by the Manager of Environmental Standards Division and/or the Office of Drinking Water
3. INITIAL chlorine, turbidity and temperature only tested at the required 39 sample locations.
4. NR-No Result due to laboratory/analyst error.
5. NA-Not Analyzed.

EMERGENCY REPORTING IS REQUIRED WHERE A POTENTIAL HEALTH RISK IS INVOLVED. FOLLOW THE INSTRUCTIONS OF YOUR DRINKING WATER OFFICER ON SITUATIONS REQUIRING IMMEDIATE REPORTING

DISTRIBUTION

FORWARD THE ORIGINAL TO THE DRINKING WATER OFFICER WITH THE MONTHLY COMPLIANCE SUBMISSIONS.

Contact the Drinking Water Officer for any comments, questions or concerns

REFERENCE: ODW-RF-016

Embrace the Spirit • Vivez l'esprit

Environmental Standards Division • Division des normes environnementales
2230 Main Street. • 2230, rue Main • Winnipeg • Manitoba R2V 4T8
fax/téléc. (204) 339-2147 • www.winnipeg.ca

SampleName	Sample Number	Date Sampled	bacColiEsch-QT (MPNU/100mL)	bacColiTotal-QT (MPNU/100mL)	bacHPC (cfu/mL)	Chlorine, Free (mg/L)	Chlorine, Total (mg/L)	Temperature (°C)	Turbidity (ntu)	Time Sped (hrs)
WC02 [REDACTED]	401469	07-Jul-14	<1	2	<10	0.83	1.03	14.0	0.18	10:30
WC02 [REDACTED]	402049	09-Jul-14	<1	<1	<10	0.74	0.98	15.7	0.23	14:17