



Dr. Khalida Hai-Santiago c/o Angela Peck
300 Carlton Street (Room 4068)
Winnipeg, Manitoba
R3B 3M9

October 7, 2021

RE: THIRD QUARTER 2021 CITY OF WINNIPEG FLUORIDE MONITORING DATA

As a participant in the Provincial Water Fluoridation Program, the City of Winnipeg Water and Waste Department hereby submits the following fluoride monitoring data on analyses conducted by the Environmental Standards Division.

LOCATION	SAMPLE NUMBER	DATE	RESULT (MG/L F)
Distribution System (Composite – 39 Locations)	405101	5-Jul-21	0.72
	406830	12-Jul-21	0.72
	408698	19-Jul-21	0.72
	410615	26-Jul-21	0.73
	412465	3-Aug-21	0.71
	414269	9-Aug-21	0.72
	416089	16-Aug-21	0.71
	417941	23-Aug-21	0.72
	419638	30-Aug-21	0.76
	421430	7-Sep-21	0.71
	423160	13-Sep-21	0.75
	424924	20-Sep-21	0.73
	426692	27-Sep-21	0.71

If you have any questions on the foregoing, please call Ms. Nancy Crawford, Compliance Reporting Branch Head, at 204-986-4807.

Yours sincerely,

*Original signed by R. Grosselle
(Signed original available upon request)*

R. Grosselle
Manager of Environmental Standards

cc: T. Shanks, P.Eng. (email)